



**Huntsville/Lake of Bays Fire Departments have met the criteria for accreditation of:**

Fire Department Water Tanker Shuttle Accreditation **equivalency** - utilizing static water resources and portable supply pumps to supply a minimum of 200 gallons per minute for a 2-hour duration non-stop.

**Note:** this accreditation is only valid for the fire stations listed below and for dwelling units only. The dwelling unit being protected utilizing a static water supply source **must be located within 305 meters (1000 feet) of an easily accessible water source** via roadway, trail or access path, unless the fire department has approved other means of access.

Other considerations may be required by individual insurance companies.

- Huntsville Station # 1 (Huntsville), 1 Payne Drive, Huntsville
- Huntsville Station # 3 (Port Sydney) 387 South Mary Lake Rd, Port Sydney
- Lake of Bays Station # 20 (Port Cunnington) 1230 Fox Point Road, Dwight
- Lake of Bays Station # 30 (Hillside) 1003 Limberlost Road, Dwight
- Lake of Bays Station # 40 (Baysville) 10 University Street, Baysville

Sincerely,

Stephen Hernen, Fire Chief

**Tanker shuttle accreditations are accepted by almost all major Insurance companies and most of the smaller insurers in Canada.**